



OFFICE OF THE DEPUTY FIRE OFFICER,
CENTRAL RANGE,
BUXI BAZAR, CUTTACK, 753001.

No. X-2-B-29-2018/ 526 /CR. CTC.

Date: 16 / 07/2020

To

The Principal,
DAV Padmabati Public School,
Mania, Uchapada, Ps-Tangi, Dist-Cuttack.

Ref: Your office L. No- DAV(TANGI)/145/2020, Dt.14.07.2020.

Sub: -Issuance of Fire Safety Certificate in respect of Primary Block of DAV Padmabati Public School, Mania, Uchapada, Ps-Tangi, Dist-Cuttack.

Madam,


With reference to the letter and subject cited above this is to intimate that you have applied for issuance of Fire Safety Certificate in respect of Primary block i.e. Block-1 of DAV Padmabati Public School, Mania, Uchapada, Ps-Tangi, Dist-Cuttack. In this connection a team of fire Service Officers had been to the premises on 14.07.2020. During inspection following information has been observed.

- i) The built up area of the school building is 960m².
- ii) The height of the said building is 3.40 mtrs.
- iii) The building is functioning in Ground floor.


As such the above said educational building is not covered under the purview of Odisha Fire Prevention and Fire Safety (Amendment) Rules-2019. Hence, Fire Safety Certificate is not required for the existing Primary block (i.e. Block-1) building of DAV Padmabati Public School. However, all Fire Protection and Fire Safety measures must be taken as per NBCI-2016.

This is for favour of kind information please.

Yours faithfully,


(T.K. Babu)

Deputy Fire Officer,
Central Range, Cuttack.


HEAD
D.A.V. PADMABATI PUBLIC SCHOOL
Mania, Tangi, Cuttack

Scanned with CamScanner